

HIMACHAL PRADESH  
PUBLIC WORKS DEPARTMENT

No. PWF/CB/WA/Building Safety Certificate/2023:- 657-58 Dated:- 19/05/23

To,

The Principal,  
De- Montreal Convent School,  
Bari Tehsil Fatehpur,  
Dist. Kangra HP

Subject: - Regarding issue of building Safety Certificate for the year 2023-24

Sir,

With reference to your office letter No. Nil dated 16-05-2023 and as reported by the Assistant Engineer, Rehan Sub Division Rehan. The building of the De- Montreal Convent School, Bari Tehsil Fatehpur Distt. Kangra (HP) was inspected by the Assistant Engineer Rehan Sub Division HPPWD Rehan along with Junior Engineer of Rehan Section. No structural drawing approved by the competent Govt. Certified Engineer have been Produced at the time of inspection. Moreover no assistance was taken from PWD for constructing the building. This structure is a non-engineered structure. Hence the structural safety of this building cannot be ensured specifically from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However as per visual inspection the building seems to be safe at present only. No Officer /Official of this department will attend plea in any Hon' ble Court of law in case of any dispute.

*VK*  
Executive Engineer  
Fatehpur Division, HPPWD,  
Fatehpur

Copy to the Assistant Engineer, Rehan Sub Division HPPWD, Rehan for information with reference to his office letter No 104 dated 17-05-2023.

DA/Nil

Executive Engineer,  
Fatehpur Division, HPPWD,  
Fatehpur